



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

## BACnet Testing Laboratories Product Listing

*This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BACnet International website.*

### Listing Information (BTL-30647-1)

Vendor		Listing Status
AB Regin Bangårdsv. 35 428 22 Kålleröd Sweden		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of November 2014	Revision 14 (135-2012)	May 2018

Product Name	Model Numbers	Firmware version
EXO family of programmable controllers	EXOcompact C152T-3, C152DT-3, C283TM-3, C282T-3, C283T-3, C282DT-3, C283DTM-3, C283DT-3	3.4.0.8
	EXOcompact Ardo XCA152W-4, XCA152DW-4, XCA282W-4, XCA282DW-4 XCA283W-4, XCA283DW-4, XCA283DWM-4, XCA203W-4	
	EXOcompact Eedo XCE163W-1	
	EXOcompact Vido XCV193WM-2, XCV193DWM-2	
	EXOdos XF192T-1, XF193TM-1, XF193DTM-1, XF192DT-1	
	EXOclever EC-PU4	

## Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All models

## BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	Change Of Value-B	DS-COV-B
	Change Of Value Property-B	DS-COVP-B

Alarm and Event Notification	Notification Internal-B	AE-N-I-B
	Acknowledge-B	AE-ACK-B
	Information-B	AE-INFO-B

Scheduling	Internal-B	SCHED-I-B
------------	------------	-----------

Device Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	ReinitializeDevice-B	DM-RD-B
	List Manipulation-B	DM-LM-B

## Object Type Support

Analog Input	Analog Value	Binary Input
Binary Value	Calendar	Characterstring Value
Device	Integer Value	Multi-State Input
Multi-State Value	Notification Class	Positive Integer Value
Schedule	Structured View	

## Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	Register as Foreign Device
MS/TP Master and Slave	9600, 19200, 38400, 76800, 115200

## Character Set Support

ISO 10646 (UTF-8)
-------------------