



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the Manufacturer's PICS statement on the BACnet International website.

Listing Information (BTL-30452)

| | | |
|--|--------------------------|----------------|
| Vendor | | Listing Status |
| Belimo Automation AG Brunnenbachstrasse 1 8340 Hinwil Switzerland | | Listed Product |
| Test Requirements | BACnet Protocol Revision | Date Tested |
| Requirements as of May 2018 | Revision 12 (135-2010) | August 2018 |

| Product Name | Model Numbers | Software Version |
|-------------------|--|------------------|
| General Air Water | x^1 24A-MOD- x^2 where x^1 is AVK, GM, GR, LM, LR, NH, NR, NV, NVK, SF, SM, SR, SRF x^2 is null, 5, or J6 | 03.03.0006 |

Device Profiles

| Profile | Model Numbers |
|--|---------------|
| BACnet Application Specific Controller (B-ASC) | All models |

BIBBs Supported

| | | |
|--------------|-------------------------|----------|
| Data Sharing | ReadProperty-B | DS-RP-B |
| | ReadPropertyMultiple-B | DS-RPM-B |
| | WriteProperty-B | DS-WP-B |
| | WritePropertyMultiple-B | DS-WPM-B |
| | Change Of Value-B | DS-COV-B |

| | | |
|-------------------|------------------------------|----------|
| Device Management | Dynamic Device Binding-B | DM-DDB-B |
| | Dynamic Object Binding-B | DM-DOB-B |
| | DeviceCommunicationControl-B | DM-DCC-B |

Object Type Support

| | | |
|--------------------|-------------------|-------------------|
| Analog Input | Analog Output | Analog Value |
| Binary Input | Device | Multi-State Input |
| Multi-State Output | Multi-State Value | |

Data Link Layer Options

| Media | Options |
|--------------|-----------------------------------|
| MS/TP Master | 9600, 19200, 38400, 76800, 115200 |

Character Set Support

| |
|-------------------|
| ISO 10646 (UTF-8) |
|-------------------|