



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

## BACnet Testing Laboratories Product Listing

*This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BI website.*

### Listing Information (BTL-30408)

Vendor		Listing Status
Contemporary Controls 2431 Curtiss Street Downers Grove, IL 60515 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of August 2012	Revision 12 (135-2010)	September 2014

Product Name	Model Number(s)	Software Version
BASstat	BAST-221C-B2, BAST-421A-B2	1.40

### Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All models

### BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RMP-B
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B

Device and Network Management	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B

## Object Type Support

Analog Input	Analog Value	Multi-state Value
Binary Input	Binary Value	Device

## Data Link Layer Options

Media	Options
MS/TP master	9600, 19200, 38400, 57600, 76800

## Character Set Support

ISO 10646 (UTF-8)
-------------------