

BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International (BI). BTL is a registered trademark of BI.

# BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BI website.

#### **Listing Information (BTL-30317)**

Vendor		Listing Status
Johnson Controls 507 E Michigan St Milwaukee, WI 53202 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of November 2014	Revision 12 (135-2010)	February 2018

Product Name	Model Numbers	Software Version
Advanced Application Field Equipment Controller (FAC)	MS-FAC2513-0, MS-FAC3613-0	10.3

#### **Device Profiles**

Profile	Model Numbers
BACnet Advanced Application Controller (B-AAC)	All models

### **BIBBs Supported**

	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
Data Sharing	WriteProperty-A	DS-WP-A
Data Sharing	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	COV-B	DS-COV-B
	COV-Unsubscribed-B	DS-COVU-B

	Notification Internal-B	AE-N-I-B
	ACK-B	AE-ACK-B
Alarm and Event	Alarm Summary-B	AE-ASUM-B
Notification	Enrollment Summary-B	AE-ESUM-B
	Information-B	AE-INFO-B
	Event Log - Internal - B	AE-EL-I-B
0 1 1 "	Internal-B	SCHED-I-B

Cobodulina	internal-b	SCHED-I-B
Scheduling	External-B	SCHED-E-B

Tranding	Viewing and Modifying Trends Internal-B	T-VMT-I-B
Trending	Automated Trend Retrieval-B	T-ATR-B

	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
Device Management	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Restart-B	DM-R-B
	List Manipulation-B	DM-LM-B

### **Object Type Support**

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Calendar	Device	Event Log
File	Multi-State Value	Notification Class
Schedule	Trend Log	

### **Data Link Layer Options**

Media	Options
MS/TP Master	9600, 19200, 38400, 76800

## **Character Set Support**

		_
100 40040 (LITE 0)		
ISO 10646 (UTF-8)		
100 100 10 (011 0)		
ISO 10646 (UCS-2)		
ISO 10646 (UCS-2)		
12 2 12 12 (2 2 3 <b>-</b> )		