

BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

Listing Information (BTL-31292)

Vendor		Listing Status
Johnson Controls Inc. 5757 N. Green Bay Ave. Milwaukee, WI 53209 USA		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of February 2021	Revision 18	April 2022

Product Name	Model Numbers	Firmware version
Input/Output Module (IOM)	MS-IOM2723-0, MS-IOM3723-0, MS-IOM3733-0	11.0.0.729

Device Profiles

Profile	Model Numbers
BACnet Smart Actuator (B-SA)	All models

BIBBs Supported

-	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
Data Sharing	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	Change Of Value-B	DS-COV-B
	Change Of Value Property-B	DS-COVP-B
	Change Of Value Unsubscribed-B	DS-COVU-B

Dynamic Device Binding-A	DM-DDB-A
Dynamic Device Binding-B	DM-DDB-B
Dynamic Object Binding-B	DM-DOB-B
DeviceCommunicationControl-B	DM-DCC-B
TimeSynchronization-B	DM-TS-B
UTCTimeSynchronization-B	DM-UTC-B
ReinitializeDevice-B	DM-RD-B
Restart-B	DM-R-B
List Manipulation-B	DM-LM-B
	Dynamic Device Binding-B Dynamic Object Binding-B DeviceCommunicationControl-B TimeSynchronization-B UTCTimeSynchronization-B ReinitializeDevice-B Restart-B

Object Type Support

Accumulator	Analog Input	Analog Output
Analog Value	Binary Input	Binary Output
Binary Value	Device	File
Multi-State Value	Network Port	

Data Link Layer Options

Media	Options
MS/TP Master	9600, 19200, 38400, 76800

Character Set Support

ISO 10646 (UCS-2)