



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

Listing Information (BTL-31213)

Vendor		Listing Status
Quantum Automation (Asia) Pte. Ltd. 9 Senoko Drive Singapore 758197		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of February 2024	Revision 12 (135-2010)	August 2018

Product Name	Model Numbers	Firmware version
iCON-3400PB-BC Programmable Building Controller	iCON-3400PB-BC	10.13.00

Device Profiles

Profile	Model Numbers
BACnet Building Controller (B-BC) BACnet Router (B-RTR)	All models

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	Change Of Value-B	DS-COV-B
Change Of Value Unsubscribed-A	DS-COVU-A	

Alarm and Event Notification	Notification Internal-B	AE-N-I-B
	Acknowledge-B	AE-ACK-B
	Enrollment Summary-B	AE-ESUM-B
	Information-B	AE-INFO-B
	Configurable Recipient Lists-B	AE-CRL-B

Scheduling	Internal-B	SCHED-I-B
	External-B	SCHED-E-B

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
	Automated Trend Retrieval-B	T-ATR-B

Device Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-A	DM-DOB-A
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	Connection Establishment-A	NM-CE-A
	Router Configuration-B	NM-RC-B
Foreign Device Registration-A	NM-FDR-A	

Object Type Support

Accumulator	Analog Input	Analog Output
Analog Value	Binary Input	Binary Output
Binary Value	Calendar	Device
File	Loop	Notification Class
Program	Schedule	Trend Log

Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	Register as Foreign Device BACnet/IP, 'DIX' Ethernet
MS/TP Master	9600, 19200, 38400, 76800, 115200

Character Set Support

ISO 10646 (UTF-8)
ISO 10646 (UCS-2)