



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Products. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BACnet International website.

Listing Information (BTL-30212)

Vendor Reliable Controls Corporation 120 Hallowell Road Victoria, BC V9A 7K2 Canada		Listing Status Listed Product
Test Requirements Requirements as of September 2014	BACnet Protocol Revision Revision 9	Date Tested May 2015

Product Name SMART-Space Controller	Model Number(s) SSC, SSCE, SSCP	Software Version 8.02
--	------------------------------------	--------------------------

Device Profiles

Profile BACnet General (B-GENERAL)	Model Numbers All models
---------------------------------------	-----------------------------

BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	WriteProperty-B	DS-WP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WritePropertyMultiple-B	DS-WPM-B

Scheduling	Schedule-Internal-B	SCHED-I-B
------------	---------------------	-----------

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
	Viewing and Modifying Multiple Values Internal-B	T-VMMV-I-B

Device and Network Management	DeviceCommunicationControl-B	DM-DCC-B
	ReinitializeDevice-B	DM-RD-B
	TimeSynchronization-B	DM-TS-B
	UTC TimeSynchronization-B	DM-UTC-B
	Backup and Restore-B	DM-BR-B

Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Device	File	Loop
Multi-state Value	Program	
Schedule	Trend Log	Trend Log Multiple

Data Link Layer Options

Media	Options
MS/TP Slave	9600, 19200, 38400, 76800

Character Set Support

ANSI X3.4 / ISO 10646 (UTF-8)
