



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.

Listing Information (BTL-31174)

Vendor		Listing Status
SE-Elektronik GmbH Eythstraße 16 73037 Göppingen Germany		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of June 2023	Revision 15	April 2024

Product Name	Model Numbers	Firmware version
BACnet Building Controller E-DDC M7	E-DDC FG11, E-DDC FG12, E-DDC FG12 V1, E-DDC FG11M, E-DDC FG11M V1, E-DDC FG13, E-DDC FG13M, E-DDC FG13M V1, E-DDC 12, E-DDC 13, E-DDC 13M	V03.08.32

Device Profiles

Profile	Model Numbers
BACnet Building Controller (B-BC) BACnet Router (B-RTR) BACnet Broadcast Management Device (B-BBMD)	All models

BIBBs Supported

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-A	DS-WPM-A
	WritePropertyMultiple-B	DS-WPM-B
	Change Of Value-A	DS-COV-A
	Change Of Value-B	DS-COV-B
	Change Of Value Property-A	DS-COVP-A
	Change Of Value Property-B	DS-COVP-B
	Change Of Value Unsubscribed-A	DS-COVU-A
	Change Of Value Unsubscribed-B	DS-COVU-B

Alarm and Event Notification	Notification-A	AE-N-A
	Notification Internal-B	AE-N-I-B
	Notification External-B	AE-N-E-B
	Acknowledge-B	AE-ACK-B
	Alarm Summary-B	AE-ASUM-B
	Enrollment Summary-B	AE-ESUM-B
	Information-B	AE-INFO-B
	Event Log-Internal-B	AE-EL-I-B
	Event Log-External-B	AE-EL-E-B
	Configurable Recipient Lists-B	AE-CRL-B

Scheduling	Internal-B	SCHED-I-B
	External-B	SCHED-E-B

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
	Viewing and Modifying Trends External-B	T-VMT-E-B
	Automated Trend Retrieval-B	T-ATR-B
	Viewing and Modifying Multiple Values Internal-B	T-VMMV-I-B
	Viewing and Modifying Multiple Values External-B	T-VMMV-E-B
Automated Multiple Value Retrieval-B	T-AMVR-B	

Device Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-A	DM-DOB-A
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-A	DM-TS-A
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-A	DM-UTC-A
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	Restart-B	DM-R-B
	List Manipulation-B	DM-LM-B
	Object Creation and Deletion-B	DM-OCD-B
	Automatic Time Synchronization-A	DM-ATS-A
	Manual Time Synchronization-A	DM-MTS-A
Router Configuration-B	NM-RC-B	
BBMD Configuration-B	NM-BBMD-C-B	

Object Type Support

Accumulator	Analog Input	Analog Output
Analog Value	Averaging	Binary Input
Binary Output	Binary Value	Bitstring Value
Calendar	Command	Date Value
Device	Event Enrollment	Event Log
File	Group	Integer Value
Loop	Multi-State Input	Multi-State Output
Multi-State Value	Notification Class	Positive Integer Value
Program	Pulse Converter	Schedule
Structured View	Time Value	Trend Log
Trend Log Multiple		

Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	BBMD Register as Foreign Device BACnet/IP, 'DIX' Ethernet
MS/TP Master	9600, 19200, 38400, 57600, 76800, 115200

Character Set Support

ANSI X3.4 ISO 8859-1 ISO 10646 (UCS-4) ISO 10646 (UCS-2) ISO 10646 (UTF-8)
--