



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

BACnet Testing Laboratories Product Listing

This product has been tested at a qualified BACnet Testing Laboratory and found to comply with all the necessary interoperability requirements in place on the published test date. This listing represents the tested capability of the Listed Product. For information on additional functionality that was not covered in the test process, refer to the manufacturer's PICS statement on the BACnet International website.

Listing Information (BTL-25122)

Vendor		Listing Status
Trane 4833 White Bear Parkway White Bear Lake, MN 55110 United States		Listed Product
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of September 2014	Revision 14	January 2015

Product Name	Model Number(s)	Software Version
Tracer™ UC400 Programmable Controller	UC400	8.0

Device Profiles

Profile	Model Numbers
BACnet Application Specific Controller (B-ASC)	All Devices

BIBBs Supported

Data Sharing	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	COV-B	DS-COV-B

Alarm and Event Management	Alarm and Event-Notification Internal-B	AE-N-I-B
	Alarm and Event-ACK-B	AE-ACK-B
	Alarm and Event-Alarm Summary-B	AE-ASUM-B
	Alarm and Event-Information-B	AE-INFO-B

Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
	Automated Trend Retrieval-B	T-ATR-B

Device and Network Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	List Manipulation-B	DM-LM-B
Object Creation and Deletion-B	DM-OCD-B	

Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Device	Event Enrollment	File
Multi-state Input	Multi-state Output	Multi-state Value
Notification Class	Trend Log	

Data Link Layer Options

Media	Options
MS/TP master	9600, 19200, 38400, 76800
ZigBee	

Character Set Support

ISO 10646 (UTF-8)
