

BACnet CONFORMANCE CERTIFICATE



No. BTL-31319

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.19. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 23.3 and the BTL Testing Policies, see Test Report number TC51418 of Protocol Test Lab.

Product name (B-BC,B-RTR,B-BBMD,B-GW)
OptiFlex™ BACnet Hardware Integrator
Model(s) OFHI-A
Firmware version
108.04.20156
Vendor
Automated Logic Corporation
1150 Roberts Blvd.
Kennesaw, GA 30144, USA

This certificate is valid until **31-Mar-2030**.

14-Mar-2025

Date of Initial Certification

Dipl.-Ing. G. Weinmann
Head of Certification Body