

BACnet CONFORMANCE CERTIFICATE



No. BTL-31318

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.12. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 23.3 and the BTL Testing Policies, see Test Report number BAC01039 of TÜV SÜD Industrie Service GmbH.

Product name (B-ASC)
NovoCon
Model(s) S, M, L, L-SU, L-SD, XL
Firmware version
BACnet 2.10
Vendor
Danfoss A/S
Nordborgvej 81
6430 Nordborg, Denmark

This certificate is valid until **31-Mar-2030**.

14-Mar-2025

Date of Initial Certification

A handwritten signature in blue ink, appearing to read 'G. Weinmann', is written over a horizontal line.

Dipl.-Ing. G. Weinmann
Head of Certification Body