

BACnet CONFORMANCE CERTIFICATE



No. BTL-31204

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.15. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 20.0 and the BTL Testing Policies, see Test Report number TC51324 of Protocol Test Lab.

Product name (B-AAC)
SOLSTYCE Series
Model(s) SCY-1DALI-24V, SCY-2DALI-24V, SCY-1DALI, SCY-2DALI
Firmware version
Application Software Version 2.0.0
Firmware Revision 15.0.2.0
Vendor
DISTECH CONTROLS Inc.
4205 Place de Java
Brossard, Quebec, Canada, J4Y 0C4

This certificate is valid until **31-Mar-2028**.

25-Jun-2024

Date of Initial Certification

A handwritten signature in blue ink, appearing to be 'G. Weinmann', is written over a horizontal line.

Dipl.-Ing. G. Weinmann
Head of Certification Body