

# BACnet CONFORMANCE CERTIFICATE



**No. BTL-31072**

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.16. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 20.0 and the BTL Testing Policies, see Test Report number BAC01019 of TÜV SÜD Industrie Service GmbH.

Product name (B-ASC)
<b>SKIA Controller</b>
<b>Model(s) SK8CD, SK8CE, SK8CM, SK8VD, SK8VE, SK8VM, SK8CE-UO, SK8CD-UO, SK8CM-UO, SK8PM, SK18CD, SK18CE, SK18CM, SK32CD, SK32CE, SK32CM</b>
Firmware version
<b>5.1.a.19</b>
Vendor
<b>Innotech</b>
<b>12 McKechnie Drive, Eight Mile Plains Brisbane, Queensland, 4113, Australia</b>

This certificate is valid until **31-Mar-2028**.

**12-Oct-2023**

Date of Initial Certification

A handwritten signature in blue ink, appearing to be 'G. Weinmann', is written over a horizontal line.

Dipl.-Ing. G. Weinmann  
Head of Certification Body