


# BACnet CONFORMANCE CERTIFICATE



## No. BTL-30695

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.18. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 16.1 and the BTL Testing Policies, see Test Report number TC50982 of Protocol Test Lab.

Product name (B-AAC)
<b>Facility Explorer VAV Box Controller</b>
<b>Model(s) F4-CVM03050-0, F4-CVM03050-0P</b>
Firmware version
<b>9.0.0.1039</b>
Vendor
<b>Johnson Controls</b>
<b>507 E. Michigan Street</b>
<b>Milwaukee, WI 53202, USA</b>

This certificate is valid until **31-Mar-2026**.

**25-Feb-2021**

Date of Initial Certification

A handwritten signature in blue ink, appearing to be 'G. Weinmann'.

Dipl.-Ing. G. Weinmann  
Head of Certification Body