


# BACnet CONFORMANCE CERTIFICATE



## No. BTL-31210


WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.14. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 23.0 and the BTL Testing Policies, see Test Report number TC51365 of Protocol Test Lab.

Product name (B-BC)
<b>DPG1024</b>
<b>Model(s) DPG1024</b>
Firmware version
<b>1.28.59</b>
Vendor
<b>Saia-Burgess Controls AG</b>
<b>Route Jo-Siffert 4</b>
<b>1762 Givisiez, Switzerland</b>

This certificate is valid until **31-Mar-2029**.

**10-Jul-2024**  
Date of Initial Certification

  
Dipl.-Ing. G. Weinmann  
Head of Certification Body

