

BACnet CONFORMANCE CERTIFICATE



No. BTL-31211


WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.16. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 23.1 and the BTL Testing Policies, see Test Report number TC51400 of Protocol Test Lab.

Product name (B-OD)
Desigo Control Point
Model(s) PXM30.E, PXM30-1, PXM40.E, PXM40-1, PXM50.E, PXM50-1, PXG3.W100-1, PXG3.W200-1, PXG3.W100-2, PXG3.W200-2
Firmware version
02.21.194.20
Vendor
Siemens
Theilerstrasse 1a
6300 Zug, Switzerland

This certificate is valid until **31-Mar-2030**.

10-Jul-2024
Date of Initial Certification


Dipl.-Ing. G. Weinmann
Head of Certification Body