

BACnet CONFORMANCE CERTIFICATE



No. BTL-31264

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.16. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 23.1 and the BTL Testing Policies, see Test Report number TC51401 of Protocol Test Lab.

Product name (B-BC,B-BBMD,B-RTR,B-SCHUB)
Desigo Automation PXC5.E24.A, PXC7.E400.A and PXC4.E16.A Automation Stations
Model(s) PXC5.E24.A, PXC7.E400.A, PXC4.E16.A
Firmware version
02.20.223.1
Vendor
Siemens
Theilerstrasse 1a
6300 Zug, Switzerland

This certificate is valid until **31-Mar-2030**.

07-Nov-2024

Date of Initial Certification

A handwritten signature in blue ink, appearing to be 'G. Weinmann', is written over a horizontal line.

Dipl.-Ing. G. Weinmann
Head of Certification Body