


# BACnet CONFORMANCE CERTIFICATE



## No. BTL-31303

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.24. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 23.3 and the BTL Testing Policies, see Test Report number TC51407 of Protocol Test Lab.

Product name (B-BC,B-BBMD,B-RTR,B-SCHUB)
<b>Tracer®</b>
<b>Model(s) SC+, Concierge</b>
Firmware version
<b>R24.V5</b>
Vendor
<b>Trane Technologies / Trane U.S. Inc.</b>
<b>4833 White Bear Parkway</b>
<b>St. Paul, MN 55110, USA</b>

This certificate is valid until **31-Mar-2030**.

**10-Jan-2025**

Date of Initial Certification

Dipl.-Ing. G. Weinmann  
Head of Certification Body